



EXPOSE A MINIMUM OF 12" OF EXISTING REINFORCING AND TIE TO THE PROPOSED REINFORCING WITH 6" SPLICE OR DRILL AND PIN 12" O.C. WITH A MINIMUM 12" DEPTH USING 24" LONG #4 BARS WITH 6" SPLICE, INSTALLED WITH NON-SHRINK GROUT OR EPOXY CEMENT AS SPECIFIED BY CONNDOT STANDARD SPECIFICATIONS.

#4 BARS 12" O.C. BOTH WAYS, TOP AND BOTTOM 2" COVER TOP AND BOTTOM MINIMUM

8" MINIMUM OR MATCH EXISTING IF GREATER

12" PROCESSED AGGREGATE BASE MIN. WITH 4" LIFTS MEETING 95% COMPACTION

CONCRETE PAVEMENT

NOTE:
 PAVING WILL BE CURB TO CURB FOR LENGTH OF PROJECT WHEN ROADWAY HAS BEEN PAVED WITHIN THE LAST 5 YEARS OR HAS A PCI VALUE GREATER THAN OR EQUAL TO 80

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL

**CONCRETE PAVEMENT
 RECONSTRUCTION**

TOWN OF GREENWICH, CONNECTICUT
 ENGINEERING DIVISION
 DEPARTMENT OF PUBLIC WORKS