



CROSS SECTION

N.T.S.

NOTES:

TEMPORARY PAVEMENT SHALL BE PLACED AT THE END OF EACH CONSTRUCTION DAY AT THE LOCATION DETERMINED BY THE ENGINEER. THE TEMPORARY PAVEMENT SECTION SHALL BE A 14" MINIMUM THICKNESS OF PROCESSED AGGREGATE BASE AND 2" THICKNESS OF CLASS 2 BITUMINOUS CONCRETE.

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL

**TEMPORARY PAVEMENT  
REPAIR**

TOWN OF GREENWICH, CONNECTICUT  
ENGINEERING DIVISION  
DEPARTMENT OF PUBLIC WORKS