



**NOTES:**

1. THIS DETAIL IS TO BE USED FOR CEMENT MASONRY WALL TO BE CONSTRUCTED ALONG THE SHORELINE.
2. REINFORCING TO HAVE 3" COVER EXCEPT WHERE SHOWN OTHERWISE. ALL REINFORCING BARS SHALL BE SPLICED A MINIMUM OF 30 DIAMETERS UNLESS NOTED OTHERWISE.
3. CONCRETE SHALL BE CLASS "A" AS DESCRIBED IN THE STATE OF CONNECTICUT DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS FORM 816
4. REINFORCEMENT BARS SHALL BE ASTM A 615/A 615M, GRADE 60(420)

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL
<b>CEMENT RUBBLE MASONRY WALL ALONG SHORELINE</b>
TOWN OF GREENWICH, CONNECTICUT ENGINEERING DIVISION DEPARTMENT OF PUBLIC WORKS