



**NOTES:**

1. GRANITE CURB SHALL HAVE 1/4" BUZZED EDGE.
2. 6" CURB REVEAL REQUIRED UNLESS OTHERWISE DIRECTED
3. MINIMUM LENGTH OF STRAIGHT CURB SHALL BE 3'-0" AND RADIUS CURB SHALL BE 2'-6"
4. JOINTS IN GRANITE CURB SHALL BE GROUTED. LEAVE OPEN JOINT APPROXIMATELY EVERY 30' O.C. TO ALLOW FOR EXPANSION.
5. VERTICAL AND HORIZONTAL ALIGNMENT OF ALL CURBS AND BERMS TO BE AS APPROVED.

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL

**GRANITE CURB**

TOWN OF GREENWICH, CONNECTICUT  
ENGINEERING DIVISION  
DEPARTMENT OF PUBLIC WORKS