



NOTES:

1. 6" CURB REVEAL REQUIRED UNLESS OTHERWISE DIRECTED
2. MINIMUM LENGTH OF STRAIGHT CURB SHALL BE 3'-0" AND RADIUS CURB SHALL BE 2'-6"
3. JOINTS IN GRANITE CURB SHALL BE GROUTED. LEAVE OPEN JOINT APPROXIMATELY EVERY 30' O.C. TO ALLOW FOR EXPANSION.
4. VERTICAL AND HORIZONTAL ALIGNMENT OF ALL CURBS AND BERMS TO BE AS APPROVED.

STANDARD CONSTRUCTION DETAIL

MOUNTABLE GRANITE CURB

TOWN OF GREENWICH, CONNECTICUT
ENGINEERING DIVISION
DEPARTMENT OF PUBLIC WORKS

SCALE = N.T.S.