



NOTES:

1. MINIMUM LENGTH OF STRAIGHT CURBS SHALL BE 3'-0" AND RADIUS CURB SHALL BE 2'-6"
2. VERTICAL AND HORIZONTAL ALIGNMENT OF ALL CURBS AND BERMS TO BE AS APPROVED.
3. JOINTS SHALL BE GROUTED. LEAVE OPEN JOINT APPROXIMATELY EVERY 30' O.C. TO ALLOW FOR EXPANSION.

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL

GRANITE SLOPE CURBS

TOWN OF GREENWICH, CONNECTICUT
 ENGINEERING DIVISION
 DEPARTMENT OF PUBLIC WORKS