



**NOTES:**

1. SPACE EXPANSION JOINTS EVERY TWENTY FEET (20').
2. 6" CURB REVEAL REQUIRED UNLESS OTHERWISE DIRECTED.
3. VERTICAL AND HORIZONTAL ALIGNMENT OF ALL CURBS AND BERMS TO BE AS APPROVED.
4. EPOXY COATED REINFORCING BAR SHALL BE ASTM A775/A775M, GRADE 60 (420).

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL
<b>CONCRETE CURB</b>
TOWN OF GREENWICH, CONNECTICUT ENGINEERING DIVISION DEPARTMENT OF PUBLIC WORKS