



NOTES:

1. GRANITE CURB SHALL HAVE 1/4" BUZZED EDGE.
2. 6" CURB REVEAL REQUIRED UNLESS OTHERWISE DIRECTED
3. MINIMUM LENGTH OF STRAIGHT CURB SHALL BE 3'-0" AND RADIUS CURB SHALL BE 2'-6"
4. JOINTS IN GRANITE CURB SHALL BE GROUTED. LEAVE OPEN JOINT APPROXIMATELY EVERY 30' O.C. TO ALLOW FOR EXPANSION.
5. INSTALL 1/2" PREFORMED NON-EXTRUDING EXPANSION JOINT FILLER (TO BE SET 1/2" BELOW SURFACE OF WALK) BOND BREAKER AT BOTTOM OF SEAL FOR FULL DEPTH OF SLAB. INSTALL JOINT SEALANT FLUSH WITH TOP OF WALK BETWEEN BUILDING AND WALK ABOVE EXPANSION JOINT.

SCALE = N.T.S.

STANDARD CONSTRUCTION DETAIL
CONCRETE SIDEWALK PINNED TO A BUILDING
TOWN OF GREENWICH, CONNECTICUT ENGINEERING DIVISION DEPARTMENT OF PUBLIC WORKS